

Confirmation

LEED

On 27 March 2017, Eurofins Product Testing A/S received a sample of a chemical anchor with the product name:

MIT-SE Plus

supplied by

Mungo Befestigungstechnik AG

The sample was supplied as being representative of the manufactured product, and it has been tested as Multipurpose Construction Adhesives in accordance with the relevant ISO 16000, ASTM D2369 and EPA method 24 testing standards (See test report no. 392-2017-00105907_H_EN_19 and 392-2017-00106007_XD_EN_19).

The test results of the tested product indicate that the product qualifies for LEED v4 specifications on VOC emissions and VOC content by complying with:


VOC emissions specifications in LEED EQ credit "Low-emitting products":

- The requirements of CDPH-IAQ (California Department of Public Health); and a TVOC below 0.5 mg/m³ in both office and class room.

VOC content specifications in LEED EQ credit "Low-emitting products":

- The requirements of SCAQMD rule 1168 (2005)

12 June 2020



Rasmus Stengaard Christensen
Analytical Service Manager, MSc in Chemistry

LEED® is the preeminent program for the design, construction, maintenance and operations of high-performance green buildings. USGBC® and the related logo are trademarks owned by the U.S. Green Building Council and are used with permission.